

CITY OF MILFORD  
SEWER COMMISSION PUBLIC HEARING  
May 25, 2016

The Sewer Commission of the City of Milford held a regular meeting on Wednesday, May 25, 2016, in Conference Room A of the Parsons Government Center, 70 West River Street, Milford, CT. Chairman Robert Carroll opened the public hearing at 6:00 p.m.

The following Commissioners were in attendance:

Chairman Robert Carroll  
Vice Chairman Donald Anderson  
Commissioner Edmund Collier  
Commissioner Lee Cooke  
Commissioner Bradford Hubler

Commissioners not in attendance: *None*

Others in attendance:

Chris Saley, Public Works Director  
Ed Kozlowski, Wastewater  
Ray Macaluso, Westcott & Mapes  
Beverly Hayes, Recording Secretary

Chairman Carroll called the meeting to order at 6 P.M. stating that Information will be presented by Westcott and Mapes, Inc. on the following projects:

Edgefield Avenue Pipe Relining

Edgefield Avenue Gravity Main/Seabreeze Avenue Reconstruction

Beaver Brook Wastewater Treatment Plant

Public Comments will be restricted to these projects only.

Chairman Carroll turned the meeting over to Ray Macaluso.

Mr. Macaluso explained that the projects have all been bonded and approved by the Board of Alderman.

Edgefield Avenue Pipe Relining

Mr. Macaluso explained the work for this project involves the rehabilitation of approximately 2,600 linear feet of existing 8-inch diameter sanitary sewer and 150 vertical feet of existing sanitary sewer manholes are to be lined in place. Also, the existing 13 manhole frames and covers are to be removed and replaced.

### Edgefield Avenue Gravity Main

Mr. Macaluso explained the work for this project involved the removal of approximately 1,700 linear feet of existing 15" RCP sanitary sewer, and replace with 18" PVC sanitary sewer and the reconstruction of approximately 110 linear feet of existing 8-inch diameter sanitary sewer on Seabreeze Avenue. The milling and paving of Edgefield Avenue and the paving of Seabreeze Avenue in the area of the sewer reconstruction will also be completed.

Commissioner Cooke asked if these are being separated, for which Mr. Macaluso responded that the Edgefield Avenue is being re-bid separate from Seabreeze Avenue.

### Beaver Brook Wastewater Treatment Plant

Mr. Macaluso explained that this project consists of removing approximately 120 linear feet of existing 16" aeration line below grade and replace with a new stainless steel 16" aeration line above grade.

*Commissioner Cooke thought that Beaver Brook had already been upgraded. Mr. Macaluso explained that they had to cut this portion out of the original project due to funding, but it is now bonded.*

Chairman Carroll called for a motion to adjourn at 6:05 P.M. Commissioner Anderson made a motion to adjourn at 6:05 P.M. with Commissioner Hubler seconding the motion. The motion carried unanimously.

Respectfully submitted,

---

Beverly A. Hayes, BS,  
Recording Secretary